

### Applicable to Exhibit Hall and EVENTSALON

1. Electrical panels must have a thirty (30") inch clearance in front. All other electrical (cords, plugs, etc.) must be of the approved type, and in accordance with the National Electrical Code.
2. Open flame devices, candles, etc. are prohibited in all assembly areas (there will be no exceptions) unless prior review by the Clark County Fire Department and devices meet requirements of the Uniform Fire Code.
3. Cooking and warming of food or beverage is prohibited unless reviewed by the Clark County Fire Department prior to the event and meet requirements of the Uniform Fire Code.
4. Storage cannot be in, under or behind booths, stages, platforms, etc. All storage (merchandise, cardboard boxes, flyers, sale sheets, etc.) must be placed in approved locations.
5. All decorations (drapery, table coverings, banners, signs, set pieces, etc.) in exhibitor booths and special events must be flame retardant. Maintain copies of flame certificates on premises as the Fire Department can require verification at any time.
6. Any structure to be suspended from the ceiling, canopies, ceiling frames and/or truss systems must be approved by the Clark County Fire Department prior to the event and meet requirements of the Uniform Fire Code. (Note: The Mandalay Bay Convention Center must approve any requests to hang structures, signs, etc. from the ceiling).
7. A copy of the plans approved by this department must be posted on the premises during the event.
8. The fire marshal of the Clark County Fire Department must review, in advance, the booth construction plans for exhibitors in The Mandalay Bay Convention Center that are using booths 400 square feet or over **or** that have a cover i.e., ceiling structure, truss system, canopy.
9. All booths with solid covers **or** that exceed 225 square feet in area, in a sprinkled building, are required to be protected within by approved automatic fire sprinklers. When determined by the Clark County Fire Department that temporary sprinkler installation is impractical, the following alternative protection may be allowed, depending upon the facility.

If any exhibiting booths have multiple levels or room(s) with enclosures, visible notification must appear on the stairway(s) or outside the room. This notice must state the maximum occupancy permissible or total weight load allowable on the second story at one time. If the second story occupancy level allows more than ten (10) people at one time, a second stairway must be present.

- a. Install approved single station smoke detectors at the interior and exterior of each covered booth. The interior smoke detectors and exterior smoke detectors must be installed in accordance with manufacturers' instructions. Smoke detectors must be interconnected in each individual booth.
  - b. Provide an approved fire extinguisher (minimum 2-A; 10-BC rating) for each covered booth. Extinguisher should be mounted near exit door.
  - c. Provide 24-hour fire watch for all covered booths in accordance with the following:
    - \* Fire watch personnel must be competently trained in the use of portable fire extinguisher and 1-1/2" fire hose lines.
    - \* Each fire watch must have radio communication with the other fire watch personnel and central control point. The central control point must have facilities to contact the fire department and in-house security personnel.
    - \* Fire watch personnel may be utilized for other than fire watch duties.
    - \* When multiple booths are used, the number of persons needed for fire watch shall be determined by the CCFD.
  - d. All materials used in the construction of the booth and all decorative materials must be noncombustible or made flame retardant. Certificates of flame retardant treatment must be submitted to the CCFD along with samples of said materials prior to construction of the booth. Certificates of flame spread /treatment of decorative items should be maintained at site for review by the CCFD.
10. The Mandalay Bay Convention Center fire extinguishers, fire hose cabinets, fire alarm pull stations, and exit signs must be visible, accessible and identified.
  11. Smoke detectors/alarms must be connected, tested and audible outside the room.
  12. Sufficient walk space must be provided within the display. Exits must not be blocked.